ENSURING DNN SOLUTION FEASIBILITY FOR OPTIMIZATION PROBLEMS WITH LINEAR CONSTRAINTS

ABSTRACT

We propose *preventive learning* as the first framework to guarantee Deep Neural Network (DNN) solution feasibility for optimization problems with linear constraints without post-processing under certain mild conditions. Without loss of generality, we focus on problems with only inequality constraints. We systematically calibrate the inequality constraints used in training, thereby anticipating DNN prediction errors and ensuring the obtained solutions remain feasible. We characterize the calibration rate and a critical DNN size, based on which we can directly construct a DNN with provable solution feasibility guarantee. We further propose an *Adversary-Sample Aware* training algorithm to improve its optimality performance. We apply the framework to solve an illustrative non-convex optimization and develop DeepOPF+ for solving the essential DC optimal power flow problem in grid operation. Simulation results over IEEE test cases show that it outperforms existing strong DNN baselines in ensuring 100% feasibility and attaining consistent optimality loss ($<0.19\%$) and speedup (up to $\times 228$) in both light-load and heavy-load regimes, as compared to a state-of-the-art solver.

1 INTRODUCTION

Recently, there have been increasing interests in employing neural networks, including deep neural networks (DNN), to solve constrained optimization problems in various problem domains, especially those needed to be solved repeatedly in real-time. The idea behind these machine learning approaches is to leverage the universal approximation capability of DNNs (Hornik et al., 1989; Leshno et al., 1993) to learn the mapping between the input parameters to the solution of an optimization problem. Then one can directly pass the input parameters through the trained DNN to obtain a quality solution much faster than iterative solvers. For example, researchers have developed DNN schemes to solve the essential optimal power flow problems in grid operation with sub-percentage optimality loss and several orders of magnitude speedup as compared to conventional solvers (Pan et al., 2020a;b; Donti et al., 2021; Chatzos et al., 2020; Lei et al., 2020). Similarly, DNN schemes also obtain desirable results for real-time power control and beam-forming design (Sun et al., 2018; Xia et al., 2019) problems in wireless communication in a fraction of time used by existing solvers.

Despite these promising results, however, a major criticism of DNN and machine learning schemes is that they usually cannot guarantee the solution feasibility with respect to all the inequality and equality constraints of the optimization problem (Zhao et al., 2020; Pan et al., 2020b). This is due to the inherent prediction errors of neural network models. Existing works address the feasibility concern mainly by incorporating the constraints violation (e.g., a Lagrangian relaxation to compute constraint violation with Lagrangian multipliers) into the loss function to guide DNN training. These endeavors, while generating great insights to the DNN design and working to some extent in case studies, can not guarantee the solution feasibility without resorting to expensive post-processing procedures, e.g., feeding the DNN solution as a warm start point into an iterative solver to obtain a feasible solution. See Sec. 2 for more discussions. To date, it remains a largely open issue of ensuring DNN solution feasibility for constrained optimizations problems.

In this paper, we address this challenge for general Optimization Problems with Linear (inequality) Constraints (OPLC) with varying problem inputs and fixed objective/constraints parameters. Since linear equality constraints can be exploited to reduce the number of decision variables without losing optimality (and removed), it suffices to focus on problems with inequality constraints. Our idea is to train DNN in a preventive manner to ensure the resulting solutions remain feasible even with prediction errors, thus avoiding the need of post-processing. We make the following contributions:

▷ After formulating OPLC in Sec. 3, we propose *preventive learning* as the first framework to ensure the DNN solution feasibility for OPLC without post-processing in Sec. 4. We systematically calibrate inequality constraints used in DNN training, thereby anticipating prediction errors and ensuring the resulting DNN solutions remain feasible.

▷ We characterize the calibration rate allowed in Sec. 4.1, i.e., the rate of adjusting (reducing) constraints limits that represents the room for (prediction) errors without violating constraints, and a sufficient DNN size for ensuring DNN solution feasibility in Sec. 4.2. We then directly construct a DNN with **provably guaranteed solution feasibility**.

▷ Observing the feasibility-guaranteed DNN may not achieve strong optimality result, in Sec. 4.3, we propose an adversarial training *Adversary-Sample Aware* algorithm to further improve its optimality **without sacrificing feasibility guarantee**. We derive a performance guarantee for the algorithm.

▷ We apply the framework to an illustrative non-convex optimization and design a DNN scheme, `DeepOPF+`, to solve DC optimal power flow (DC-OPF) problems in grid operation. Simulation results over IEEE 30/118/300-bus test cases show that it outperforms existing strong DNN baselines in ensuring 100% feasibility and attaining consistent optimality loss ($<0.19\%$) and speedup (up to $\times 228$) in both light-load and heavy-load regimes, as compared to a state-of-the-art solver.

2 RELATED WORK

There have been active studies in employing machine learning models, including DNNs, to solve constrained optimizations directly (Kotary et al., 2021b; Pan et al., 2019; 2020b; Guha et al., 2019; Zamzam & Baker, 2020; Fioretto et al., 2020; Dobbe et al., 2019; Sanseverino et al., 2016; Donti et al., 2021; Elmachtoub & Grigas, 2022; Huang et al., 2021; Huang & Chen, 2021), obtaining close-to-optimal solution much faster than conventional iterative solvers. However, these schemes usually cannot guarantee solution feasibility w.r.t. constraints due to inherent prediction errors.

Some existing works tackle the feasibility concern by incorporating the constraints violation in DNN training (Pan et al., 2020a; Donti et al., 2021). In (Nellikkath & Chatzivasileiadis, 2021a;b), physics-informed neural networks are applied to predict solutions while incorporating the KKT conditions of optimizations during training. These approaches, while attaining insightful performance in case studies, do not provide solution feasibility guarantee and may resort to expensive projection procedure (Pan et al., 2020b) or post-processing equivalent projection layers (Amos & Kolter, 2017; Agrawal et al., 2019) to recover feasibility. A gradient-based violation correction is proposed in (Donti et al., 2021). Though a feasible solution can be recovered for linear constraints, it can be computational inefficient and may not converge for general optimizations. A DNN scheme applying gauge function that maps a point in an l_1-norm unit ball to the (sub)-optimal solution is proposed in (Li et al., 2022). However, its feasibility enforcement is achieved from an computational expensive interior-point finder program. There is also a line of work (Ferrari, 2009; Yin et al., 2022; Qin et al., 2019; Limanond & Si, 1998) focusing on verifying whether the output of a given DNN satisfies a set of requirements/constraints. However, these approaches are only used for evaluation and not capable of obtaining a DNN with feasibility-guarantee and strong optimality. To our best knowledge, this work is the *first* to guarantee DNN solution feasibility without post-processing.

Some techniques used in our study (for constrained problems) are related to those for verifying DNN accuracy against input perturbations for unconstrained classification (Sheikholeslami et al., 2020). Our work also significantly differs from (Zhao et al., 2020) in we can provably guarantee DNN solution feasibility for OPLC and develop a new learning algorithm to improve solution optimality.

3 OPTIMIZATION PROBLEMS WITH LINEAR CONSTRAINTS (OPLC)

We focus on the standard OPLC formulated as (Faísca et al., 2007):

$$\min \ f(\boldsymbol{x}, \boldsymbol{\theta}) \quad \text{s.t.} \quad g_j(\boldsymbol{x}, \boldsymbol{\theta}) \triangleq \boldsymbol{a_j^T} \boldsymbol{x} + \boldsymbol{b_j^T} \boldsymbol{\theta} \leq e_j, \ j \in \mathcal{E}, \tag{1}$$

$$\text{var.} \quad \underline{x}_k \leq x_k \leq \bar{x}_k, \ k = 1, \dots, N. \tag{2}$$

$\boldsymbol{x} \in \mathcal{R}^N$ are the decision variables, $\mathcal{E}$ is the set of inequality constraints, and $\boldsymbol{\theta} \in \mathcal{D}$ are the OPLC inputs. Convex polytope $\mathcal{D} = \{\boldsymbol{\theta} \in \mathcal{R}^M | \mathbf{A}_{\boldsymbol{\theta}} \boldsymbol{\theta} \leq \boldsymbol{b}_{\boldsymbol{\theta}}, \exists \mathbf{x} : (1), (2) \text{ hold}\}$ is specified by matrix $\mathbf{A}_{\boldsymbol{\theta}}$ and vector $\boldsymbol{b}_{\boldsymbol{\theta}}$ such that $\forall \boldsymbol{\theta} \in \mathcal{D}$, OPLC in (1)-(2) admits a unique optimum.[1] The OPLC objective f is a general convex/non-convex function. For ease of presentation, we use $g_j(\boldsymbol{x}, \boldsymbol{\theta})$ to denote

---

[1] Our approach is also applicable to non-unique solution and unbounded $\boldsymbol{x}$. See Appendix A for a discussion.

Figure 1: Overview of the preventive learning framework to solve OPLC. The calibration rate is first obtained. The sufficient DNN size in ensuring universal feasibility is then determined, and a DNN model can be constructed directly with universal feasibility guarantee in this step. With the determined calibration rate and sufficient DNN size, a DNN model with enhanced optimality without sacrificing feasibility is obtained using the *Adversary Sample-Aware* algorithm.

$\boldsymbol{a_j^T x} + \boldsymbol{b_j^T \theta}.$[2] We assume that each $g_j(\boldsymbol{x}, \boldsymbol{\theta}) \leq e_j$ is active for at least one combination of $\boldsymbol{\theta} \in \mathcal{D}$ and $\boldsymbol{x}$ satisfying (2) without loss of generality (otherwise g_j is unnecessary and can be removed). We note that linear equality constraints can be exploited (and removed) to reduce the number of decision variables without losing optimality as discussed in Appendix B, it suffices to focus on OPLC with inequality constraints as formulated in (1)-(2).

The OPLC in (1)-(2) has wide applications in various engineering domains, e.g., DC-OPF problems in power systems (Pan et al., 2019) and model-predictive control problems in control systems (Bemporad et al., 2000). While many numerical solvers, e.g., those based on interior-point methods (Ye & Tse, 1989), can be applied to obtain its solution, the time complexity can be significant and limits their practical applications especially considering the problem input uncertainty under various scenarios. The observation that opens the door for DNN scheme development lies in that solving OPLC is equivalent to learning the mapping from input $\boldsymbol{\theta}$ to optimal solution $\boldsymbol{x}^*(\boldsymbol{\theta})$ (Pan et al., 2020a; Bemporad & Filippi, 2006). Thus, one can leverage the universal approximation capability of DNNs (Hornik et al., 1989; Leshno et al., 1993) to learn the input-solution mapping and apply the trained DNN to obtain the optimal solution for any $\boldsymbol{\theta} \in \mathcal{D}$ with significantly lower time complexity. See a concrete example in (Pan et al., 2020b). While DNN schemes achieve promising speedup and optimality performance, a fundamental challenge lies in ensuring solution feasibility, which is nontrivial due to inherent DNN prediction errors. In the following, we propose preventive learning as the first framework to tackle this issue and design DNN schemes for solving OPLC in (1)-(2).

4 PREVENTIVE LEARNING FOR SOLVING OPLC

We propose a preventive learning framework to develop DNN schemes for solving OPLC in (1)-(2). We calibrate inequality constraints used in DNN training, thereby anticipating prediction errors and ensuring the resulting DNN solutions remain feasible. See Fig. 2 for illustrations.

First, in Sec. 4.1, we determine the maximum calibration rate for inequality constraints, so that solutions from a preventively-trained DNN using the calibrated constraints respect the original constraints for all possible inputs.

Second, in Sec. 4.2, we determine a sufficient DNN size so that with preventive learning there exists a DNN whose worst-case violation on calibrated constraints is smaller than the maximum calibration rate, thus ensuring DNN solution feasibility. We construct a provable feasibility-guaranteed DNN model, namely DNN-FG, as shown in Fig. 1.

Third, observing DNN-FG may not achieve strong optimality performance, in Sec. 4.3, we propose an adversarial *Adversary Sample-Aware* training algorithm to further improve DNN's optimality without sacrificing feasibility guarantee, obtaining an optimality-enhanced DNN as shown in Fig. 1.

4.1 INEQUALITY CONSTRAINT CALIBRATION RATE

We calibrate each inequality limit $g_j(\boldsymbol{x}, \boldsymbol{\theta}) \leq e_j, j \in \mathcal{E}$ by a calibration rate $\eta_j \geq 0$:[3]

$$g_j(\boldsymbol{x}, \boldsymbol{\theta}) \leq \hat{e}_j = \begin{cases} e_j(1 - \eta_j), & \text{if } e_j \geq 0; \\ e_j(1 + \eta_j), & \text{otherwise.} \end{cases} \tag{3}$$

---

[2]Multiple scalars $\boldsymbol{b_j^T \theta}, j \in \mathcal{E}$ are correlated via $\boldsymbol{\theta}$. Studying varying $\boldsymbol{a_j}, \boldsymbol{b_j}, e_j$ is also a promising future work.

[3]For g_j with $e_j = 0$, one can add an auxiliary constant $\tilde{e}_j \neq 0$ such that $g_j(\boldsymbol{x}, \boldsymbol{\theta}) + \tilde{e}_j \leq \tilde{e}_j$ for the design and formulation consistency. The choice of $\tilde{e}_j$ can be problem dependent. For example, in our simulation, $\tilde{e}_j$ is set as the maximum slack bus generation for its lower bound limit in OPF discussed in Appendix L.

However, an inappropriate calibration rate could lead to poor performance of DNN. If one adjusts the limits too much, some input $\boldsymbol{\theta} \in \mathcal{D}$ will become infeasible under the calibrated constraints and hence lead to poor generalization of the preventively-trained DNN. To this end, we solve the following bi-level optimization to obtain the maximum calibration rate, such that the calibrated feasibility set of $\boldsymbol{x}$ can still support the input region, i.e., the OPLC in (1)-(2) with a reduced feasible set has a solution for any $\boldsymbol{\theta} \in \mathcal{D}$.

$$\min_{\boldsymbol{\theta} \in \mathcal{D}} \max_{\boldsymbol{x}, \nu^c} \quad \nu^c \tag{4}$$

$$\text{s.t. } (1), (2)$$
$$\nu^c \leq (e_j - g_j(\boldsymbol{\theta}, \boldsymbol{x}))/|e_j|, \ \forall j \in \mathcal{E}. \tag{5}$$

Figure 2: Left: solution of DNN trained with default OPLC ground-truth can be infeasible due to inevitable prediction errors. Right: solution of DNN trained with calibrated OPLC ground-truth ensures universal feasibility even with prediction errors.

(1)-(2) enforce the feasibility of $\boldsymbol{x}$ for input $\boldsymbol{\theta} \in \mathcal{D}$. (5) represents the maximum element-wise least redundancy among all constraints, i.e., the maximum constraint calibration rate. Therefore, solving (4)-(5) gives the maximum allowed calibration rate for all inequality constraints and $\boldsymbol{\theta} \in \mathcal{D}$.

It is challenging to solve the above bi-level problem exactly. We apply the following procedure to obtain a lower bound of its optimal objective in polynomial time. See Appendix C for details.

> Step 1. Reformulate the bi-level problem (4)-(5) to an equivalent single-level one by replacing the inner problem with its KKT conditions (Boyd & Vandenberghe, 2004).
>
> Step 2. Transform the single-level optimization problem into a MILP by replacing the bilinear equality constraints (comes from the complementary slackness in KKT conditions) with equivalent mixed-integer linear inequality constraints.
>
> Step 3. Solve the MILP using the branch-and-bound algorithm (Lawler & Wood, 1966). Let the obtained objective value be $\Delta \geq 0$ from primal feasibility (1).

Remark: (i) the branch-and-bound algorithm returns Δ (lower bound of optimal ν^{c*}) with a polynomial time complexity of $\mathcal{O}((M+4|\mathcal{E}|+5N)^{2.5})$ (Vaidya, 1989), where M and N are the dimensions of the input and decision variables, and $|\mathcal{E}|$ is the number of constraints. (ii) Δ is a lower bound to the maximum calibration rate as the algorithm may not solve the MILP exactly. Such a lower bound still guarantees that the input region is supported. (iii) If $\Delta = 0$, reducing the feasibility set may lead to no feasible solution for some inputs. (iv) If $\Delta > 0$, we can obtain a DNN with provably solution feasibility guarantee as shown in Sec. 4.2. (v) After solving (4)-(5), we set each η_j in (3) to be Δ, such uniform constraints calibration forms the *outer bound* of the minimum supporting calibration region. See Appendix D for a discussion; (vi) we observe that the branch-and-bound algorithm can actually return the exact optimal objective in <20 mins for numerical examples in Sec. 6.

4.2 SUFFICIENT DNN SIZE FOR ENSURING FEASIBILITY

In this subsection, we first model DNN with ReLU activations. Then, we introduce a method to determine the sufficient DNN size for guaranteeing solution feasibility.

4.2.1 DNN MODEL REPRESENTATION.

We employ a DNN with N_{hid} hidden layers (depth) and N_{neu} neurons in each hidden layer (width), using multi-layer feed-forward neural network structure with ReLU activation function to approximate the input-solution mapping for OPLC, which is defined as:

$$\boldsymbol{h_0} = \boldsymbol{\theta}, \ \boldsymbol{h_i} = \sigma\left(\boldsymbol{W_i}\boldsymbol{h_{i-1}} + \boldsymbol{b_i}\right), \ i = 1, \dots, N_{\text{hid}},$$
$$\tilde{\boldsymbol{h}} = \sigma\left(\boldsymbol{W_o}\boldsymbol{h}_{N_{\text{hid}}} + \boldsymbol{b_o} - \underline{\boldsymbol{x}}\right) + \underline{\boldsymbol{x}}, \hat{\boldsymbol{x}} = -\sigma\left(\bar{\boldsymbol{x}} - \tilde{\boldsymbol{h}}\right) + \bar{\boldsymbol{x}}. \tag{6}$$

$\boldsymbol{\theta}$ is the DNN input and $\boldsymbol{h_i}$ is the output of the i-th layer. $\boldsymbol{W_i}$ and $\boldsymbol{b_i}$ are the i-th layer's weight matrix and bias. $\sigma(x) = \max(x, 0)$ is the ReLU activation, taking element-wise max operation over the input vector. $\tilde{\boldsymbol{h}}$ enforces output feasibility w.r.t. the lower bounds in (2) while final output

$\hat{x}$ further satisfies upper bounds. Here we present the last two *clamp*-equivalent actions as (6) for further DNN analysis. To better include the DNN in our design to analysis the DNN performance, we adopt the technique in (Tjeng et al., 2018) to reformulate the ReLU activations expression in (6). For $i = 1, \ldots, N_{\text{hid}}$, let $\hat{\boldsymbol{h}}_i$ denote $\boldsymbol{W_i h_{i-1}} + \boldsymbol{b_i}$. The output of neuron with ReLU activation is represented as: for $k = 1, \ldots, N_{\text{neu}}$ and $i = 1, \ldots, N_{\text{hid}}$,

$$\hat{h}_i^k \le h_i^k \le \hat{h}_i^k - h_i^{\min,k}(1 - z_i^k), \tag{7}$$

$$0 \le h_i^k \le h_i^{\max,k} z_i^k, \; z_i^k \in \{0, 1\}. \tag{8}$$

Here we use superscript k to denote the k-th element of a vector. z_i^k are (auxiliary) binary variables indicating the state of the corresponding neuron, i.e., 1 (resp. 0) indicates activated (resp. non-activated). We remark that given the value of DNN weights and bias, z_i^k can be determined representing the status of each neuron (z_i^k can be either 0/1 if $\hat{h}_i^k = 0$) for each input $\boldsymbol{\theta}$. $h_i^{\max,k}/h_i^{\min,k}$ are the upper/lower bound on the neuron outputs. With (7)-(8), the input-output relationship in DNN can be represented with a set of mixed-integer linear inequalities. We discuss how to employ (7)-(8) to determine the sufficient DNN size in guaranteeing universal feasibility in Sec. 4.2.2. For ease of representation, we use $(\mathbf{W}, \mathbf{b})$ to represent DNN weights and bias in the following.

4.2.2 SUFFICIENT DNN SIZE IN GUARANTEEING UNIVERSAL FEASIBILITY.

As a methodological contribution, we propose an iterative approach to determine the sufficient DNN size for guaranteeing universal solution feasibility in the input region. The idea is to iteratively verify whether the worst-case prediction error of the given DNN model is within the room of error (maximum calibration rate), and doubles the DNN's width (with fixed depth) if not. We outline the design of the proposed approach below, under the setting where all hidden layers share the same width. Let the depth and (initial) width of the DNN model be N_{hid} and N_{neu}, respectively.

For each iteration, the proposed approach first evaluates the least maximum relative violations among all constraints for all $\boldsymbol{\theta} \in \mathcal{D}$ for the current DNN model via solving the following bi-level program:

$$\min_{\mathbf{W},\mathbf{b}} \max_{\boldsymbol{\theta} \in \mathcal{D}} \; \nu^f \tag{9}$$

$$\text{s.t.} \; (7) - (8), 1 \le i \le N_{\text{hid}}, 1 \le k \le N_{\text{neu}},$$

$$\nu^f = \max_{j \in \mathcal{E}} \{(g_j(\boldsymbol{\theta}, \hat{\boldsymbol{x}}) - \hat{e}_j)/|e_j|\}, \tag{10}$$

where (9)-(10) express the outcome of the DNN as a function of input $\boldsymbol{\theta}$. ν^f is maximum constraints violation degree among all constraints. Thus, solving (9)-(10) gives the least maximum DNN constraint violation over the input region $\mathcal{D}$. We apply gradient descent to solve the above bi-level optimization problem, see Appendix E for details. Let ρ be the obtained objective value of (9)-(10) and $(\mathbf{W}^f, \mathbf{b}^f)$ be the corresponding DNN parameters, with which we can directly construct a DNN model. Recall that the determined calibration rate is Δ, the proposed approach then verifies whether the constructed DNN is sufficient for guaranteeing feasibility by the following proposition.

Proposition 1 *Consider the DNN with N_{hid} hidden layers each having N_{neu} neurons and parameters $(\mathbf{W}^f, \mathbf{b}^f)$. If $\rho \le \Delta$, then $\forall \boldsymbol{\theta} \in \mathcal{D}$, this DNN's solution is feasible w.r.t (1)-(2).*

The proof is shown in Appendix F. Proposition 1 states that if $\rho \le \Delta$, the worst-case prediction error of current DNN model is within the room of maximum calibration rate and hence the current DNN size is sufficient for guaranteeing universal feasibility; otherwise, it doubles the widths of DNN and moves to the next iteration until $\rho \le \Delta$. Recall that the input-solution mapping for OPLC is continuous. Hence, there exists a DNN such that universal feasibility of DNN solution is guaranteed given the DNN size (width) is sufficiently large according to the universal approximation theorem (Hornik, 1991). See Appendix G for the discussion.[4] Details of the procedures are shown in Algorithm 1. After the initialization of DNN model (line 3-4), the proposed approach repeatedly compare the obtained maximum constraints violation (ρ) with the calibration rate (Δ), doubles the DNN width (line 5-7), and return the width as N_{neu}^* until $\rho \le \Delta$. Thus, we can construct a provable feasibility-guaranteed DNN model by the proposed approach, namely DNN-FG as shown in Fig. 1.

We remark that it is challenging to solve the bi-level problem (9)-(10) exactly, i.e., the obtained ρ is an upper bound of the optimal objective of (9)-(10) in each iteration. Nevertheless, as discussed in the following proposition, the upper bound is still useful for analyzing universal solution feasibility.

---

[4]One may also increase DNN depth to achieve similar universal approximation for more degree of freedom in DNN parameters. In this work, we consider increasing the DNN width for sufficient DNN learning ability.

Algorithm 1: Determining Sufficient DNN Size

1: **Input:** Δ; Initial width $N_{\text{neu}}^{\text{init}}$
2: **Output:** Determined DNN width: N_{neu}^*
3: Set $t = 0$; Set $N_{\text{neu}}^t = N_{\text{neu}}^{\text{init}}$; Obtain ρ via solving (9)-(10)
4: **while** $\rho \geq \Delta$ **do**
5:     Set $N_{\text{neu}}^{t+1} = 2 \times N_{\text{neu}}^t$; Set $t = t + 1$; Solve (9)-(10) and update ρ
6: **end while**
7: Set $N_{\text{neu}}^* = N_{\text{neu}}^t$
8: **Return:** N_{neu}^*

Proposition 2 *Assume $\Delta > 0$, Algorithm 1 is guaranteed to terminate in finite number of iterations. At each iteration t, consider the DNN with N_{hid} hidden layers each having N_{neu}^t neurons, we can obtain ρ as an upper bound to the optimal objective of (9)-(10) with a time complexity $\mathcal{O}((M + |\mathcal{E}| + 2N_{hid}N_{neu}^t + 4N)^{2.5})$. If $\rho \leq \Delta$, then the DNN with depth N_{hid} and width N_{neu}^t is sufficient in guaranteeing universal feasibility. Furthermore, one can construct a feasibility-guaranteed DNN with the corresponding obtained DNN parameters $(\mathbf{W}^f, \mathbf{b}^f)$ such that for any $\theta \in \mathcal{D}$, the solution of this DNN is feasible w.r.t. (1)-(2).*

Proposition 2 indicates ρ can be obtained in polynomial time. If $\rho \leq \Delta$, it means the current DNN size is sufficient to preserve universal solution feasibility in the input region; otherwise, it means the current DNN size may not be sufficient for the purpose and it needs to double the DNN width.

We also remark that the obtained sufficient DNN size may not be the minimal sufficient one if the above bi-level optimization problem is not solved exactly. Please refer to Appendix H for detailed discussions. In our case study in Sec. 6, we observe that the evaluated initial DNN size can always guarantee universal feasibility with a non-positive worst-case constraints violation, and we hence conduct further simulations with such determined sufficient DNN sizes.

4.3 ADVERSARY SAMPLE-AWARE ALGORITHM

While we can directly construct a feasibility-guaranteed DNN (without training) as shown in Proposition 2, it may not achieve strong optimality performance. To this end, we propose an *Adversary Sample-Aware (ASA)* algorithm to further improve the optimality performance. The algorithm leverages the ideas of adversarial learning (Chakraborty et al., 2018) and active learning (Ren et al., 2020) techniques, which adaptively incorporates adversary inputs, i.e., the inputs that cause infeasible DNN solutions, for pursuing strong optimality result while preserving universal feasibility guarantee. We outline the algorithm in the following. Denote the initial training set as $\mathcal{T}^0$, containing randomly-generated input and the corresponding ground-truth obtained by solving the calibrated OPLC (with calibration rate Δ). The proposed *ASA* algorithm first pre-trains a DNN model with the sufficient size determined by the approach discussed in Sec. 4.2.2, using the initial training set $\mathcal{T}^0$ and the following loss function $\mathcal{L}$ for each instance as the supervised learning approach:

$$\mathcal{L} = \frac{w_1}{N} \|\hat{\boldsymbol{x}} - \boldsymbol{x}^*\|_2^2 + \frac{w_2}{|\mathcal{E}|} \sum_{j \in \mathcal{E}} \max(g_j(\hat{\boldsymbol{x}}, \boldsymbol{\theta}) - \hat{e}_j, 0). \tag{11}$$

We leverage the penalty-based training idea in (11). The first term is the mean square error between DNN prediction $\hat{\boldsymbol{x}}$ and the ground-truth $\boldsymbol{x}^*$ provided by the solver for each input. The second term is the inequality constraints violation w.r.t calibrated limits $\hat{e}_j$. w_1 and w_2 are positive weighting factors to balance prediction error and penalty. Hence, training DNN by minimizing (11) can pursue a strong optimality performance as DNN prediction error is also minimized.

However, traditional penalty-based training by only minimizing (11) can not guarantee universal feasibility (Venzke et al., 2020; Pan et al., 2020b). To address this issue, the *ASA* algorithm repeatedly updates the DNN model with adversary samples, anticipating the post-trained DNNs can eliminate violations around such inputs. Specifically, given current DNN parameters, it finds the worst-case input $\boldsymbol{\theta}^i \in \mathcal{D}$ by solving the inner maximization problem of (9)-(10). Let γ be the obtained objective value. Recall that the calibration rate is Δ. If $\gamma \leq \Delta$, the algorithm terminates; otherwise, it incorporates a subset of samples randomly sampled around $\boldsymbol{\theta}^i$ and solves the calibrated OPLC with Δ, and starts a new round of training. Details of the *ASA* algorithm are shown in Appendix I. We highlight the difference between the DNN obtained in Sec. 4.2.2 and that from *ASA* algorithm as follows. The former is directly constructed via solving (9)-(10), which guarantees universal feasibility whilst without considering optimality. In contrast, the latter is expected to enhance optimality while preserving universal feasibility as both optimality and feasibility are considered during training. We further provide theoretical guarantee of it in ensuring universal feasibility in the following.

Proposition 3 *Consider a DNN model with N_{hid} hidden layers each having N_{neu}^* neurons. For each iteration i, assume such a DNN trained with the ASA algorithm can maintain feasibility at the constructed neighborhood $\hat{\mathcal{D}}^j = \{\boldsymbol{\theta}|\boldsymbol{\theta}^j \cdot (1-a) \leq \boldsymbol{\theta} \leq \boldsymbol{\theta}^j \cdot (1+a), \boldsymbol{\theta} \in \mathcal{D}\}$ around $\boldsymbol{\theta}^j$ with some small constant $a > 0$ for $\forall j \leq i$. There exists a constant C such that the algorithm is guaranteed to ensure universal feasibility as the number of iterations is larger than C.*

The proof idea is shown in Appendix J. Proposition 3 indicates that, with the iterations is large enough, the *ASA* algorithm can ensure universal feasibility by progressively improving the DNN performance around each region around worst-case input. It provides a theoretical understanding on the justifiability of the *ASA* algorithm. In practice, we can terminate the *ASA* algorithm whenever the maximum solution violation is smaller than the inequality calibration rate, which implies universal feasibility guarantee. We note that the feasibility enforcement in the empirical/heuristic algorithm achieve strong theoretical grounding while its performance can be affected by the training method chosen. Nevertheless, as observed in the case study in Appendix M, the *ASA* algorithm terminates in at most 52 iterations with 7% calibration rate, showing its efficiency in practical application.

5 PERFORMANCE ANALYSIS OF THE PREVENTIVE LEARNING FRAMEWORK

5.1 UNIVERSAL FEASIBILITY GUARANTEE

We provide the following proposition showing that the preventive learning framework generates two DNN models with universal feasibility guarantees.

Proposition 4 *Let Δ, ρ, and γ be the determined maximum calibration rate, the obtained objective value of (9)-(10) to determine the sufficient DNN size, and the obtained maximum relative violation of the trained DNN from Adversary Sample-Aware algorithm following steps in preventive framework, respectively. Assume (i) $\Delta > 0$, (ii) $\rho \leq \Delta$, and (iii) $\gamma \leq \Delta$. The DNN-FG obtained from determining sufficient DNN size can provably guarantee universal feasibility and the DNN from ASA algorithm further improves optimality without sacrificing feasibility guarantee $\forall \boldsymbol{\theta} \in \mathcal{D}$.*

Proposition 4 indicates the DNN model obtained by preventive learning framework is expected to guarantee the universal solution feasibility, which is verified by simulations in Sec. 6.

5.2 RUN-TIME COMPLEXITY

We then provide the complexity of the traditional method in solving the optimization problems with linear constraints. To the best of our knowledge, the general OPLC does not have complete and universal computational complexity results based on the existing algorithms due to their NP-hardness. To better deliver the results here, we consider the specific case of OPLC, namely the mp-QP problem, with linear constraints and quadratic objective function. We remark that the complexity of solving mp-QP provides a lower bower for the general OPLC problem. Under the given setting, the DNN based framework has a complexity of $\mathcal{O}\left(N^2\right)$ whilst the best known iterative algorithm (Ye & Tse, 1989) requires $\mathcal{O}\left(N^4 + |\mathcal{E}|M\right)$, indicating the computational complexity of the proposed framework is lower than that of traditional algorithms. The comparisons results demonstrates the efficiency of the preventive learning framework. See Appendix K for the details.

5.3 TRADE-OFF BETWEEN FEASIBILITY AND OPTIMALITY

We remark that to guarantee universal feasibility, the preventive learning framework shrinks the feasible region used in preparing training data. Therefore, the DNN solution may have a larger optimality loss due to the (sub)-optimal training data. It indicates a trade-off between optimality and feasibility, i.e., larger calibration rate leads to better feasibility but worse optimality. To further enhance DNN optimality performance, one can choose a smaller calibration rate than Δ while enlarging DNN size for better approximation ability and hence achieve satisfactory optimality and guarantee universal feasibility simultaneously.

6 APPLICATION IN SOLVING DC-OPF AND NON-CONVEX OPTIMIZATION

6.1 DC-OPF PROBLEM AND DEEPOPF+

DC-OPF is a fundamental problem for modern grid operation. It aims to determine the least-cost generator output to meet the load in a power network subject to physical and operational constraints. With the penetration of renewables and flexible load, the system operators need to handle significant uncertainty in load input during daily operation. They need to solve DC-OPF problem under many scenarios more frequently and quickly in a short interval, e.g., 1000 scenarios in 5 minutes, to obtain a stochastically optimized solution for stable and economical operations. However, iterative solvers may fail to solve a large number of DC-OPF problems for large-scale power networks fast enough for the purpose. Although recent DNN-based schemes obtain close-to-optimal solution much faster

than conventional methods, they do not guarantee solution feasibility. We design DeepOPF+ by employing the preventive learning framework to tackle this issue. Consider the DC-OPF formulation:

$$\min_{\boldsymbol{P_G},\,\Phi} \sum_{i \in \mathcal{G}} c_i\left(P_{Gi}\right) \quad \text{s.t. } \boldsymbol{P_G^{\min}} \leq \boldsymbol{P_G} \leq \boldsymbol{P_G^{\max}}, \mathbf{M} \cdot \Phi = \boldsymbol{P_G} - \boldsymbol{P_D}, -\boldsymbol{P_{\text{line}}^{\max}} \leq \mathbf{B}_{\text{line}} \cdot \Phi \leq \boldsymbol{P_{\text{line}}^{\max}}, \quad (12)$$

$\boldsymbol{P_G^{\min}} \in \mathcal{R}^{|\mathcal{B}|}$ (resp. $\boldsymbol{P_G^{\max}}$) and $\boldsymbol{P_{\text{line}}^{\max}} \in \mathcal{R}^{|\mathcal{K}|}$ are the minimum (resp. maximum) generation limits of generators[5] and branch flow limits of the set of transmission lines denoted as $\mathcal{K}$. $\mathcal{G}, \mathcal{B}$, $\mathbf{M}, \mathbf{B}_{\text{line}}$, and $\Phi \in \mathcal{R}^{|\mathcal{B}|}$ denote the set of generators, buses, bus admittance matrix, line admittance matrix, and bus phase angles, respectively. The objective is the total generation cost and $c_i\left(\cdot\right)$ is the cost function of each generator, which is usually strictly quadratic (Park et al., 1993; tpc, 2018) from generator's heat rate curve. Constraints in (12) enforce nodal power balance equations and the limits on active power generation and branch flow. DC-OPF is hence a quadratic programming and admits a unique optimal solution w.r.t. load input $\boldsymbol{P_D}$. Analogy to OPLC (1)-(2), $\sum_{i \in \mathcal{G}} c_i\left(P_{Gi}\right)$ is the objective function f in (1). $\boldsymbol{P_D}$ is the problem input θ and $(\boldsymbol{P_G}, \Phi)$ are the decision variables $\boldsymbol{x}$.

We apply the proposed preventive-learning framework to design a DNN scheme, named DeepOPF+, for solving DC-OPF problems. We refer interested readers to Appendix L for details. Denote Δ, ρ, and γ as the obtained maximum calibration rate, the obtained objective value of (9)-(10) to determine sufficient DNN size, and the maximum relative violation of the trained DNN from *Adversary Sample-Aware* algorithm in DeepOPF+ design, respectively. We highlight the feasibility guarantee and computational efficiency of DeepOPF+ in following proposition.

Corollary 1 *Consider the DC-OPF problem and DNN model defined in (6). Assume (i) $\Delta > 0$, (ii) $\rho \leq \Delta$, and (iii) $\gamma \leq \Delta$, then the DeepOPF+ generates a DNN guarantees universal feasibility for any $\boldsymbol{P_D} \in \mathcal{D}$. Suppose the DNN width is the same order of number of bus B, then DeepOPF+ has a smaller computational complexity of $\mathcal{O}\left(B^2\right)$ compared with that of state-of-the-art iterative methods $\mathcal{O}\left(B^4\right)$, where B is the number of buses.*

Corollary 1 says that DeepOPF+ can solve DC-OPF with universal feasibility guarantee at lower computational complexity compared to conventional iterative solvers,[6] as DNNs with width $\mathcal{O}(B)$ can achieve desirable feasibility/optimality. Such an assumption is validated in existing literature (Pan et al., 2019; Donti et al., 2021) and our simulation. To our best knowledge, DeepOPF+ is the first DNN scheme to solve DC-OPF with solution feasibility guarantee without post-processing. We remark that the DeepOPF+ design can be easily generalized to other linearized OPF models (Cain et al., 2012; Yang et al., 2018; Bolognani & Dörfler, 2015) .

6.2 PERFORMANCE EVALUATION OVER IEEE TEST CASES

We evaluate its performance over IEEE 30-/118-/300- bus test cases (tpc, 2018) on the input load region of $[100\%, 130\%]$ of the default load covering both the light-load ($[100\%, 115\%]$) and heavy-load ($[115\%, 130\%]$) regimes, respectively. We conduct simulations in CentOS 7.6 with a quad-core (i7-3770@3.40G Hz) CPU and 16GB RAM. We compare DeepOPF+ with five baselines on the same training/test setting: 1) Pypower: the conventional iterative OPF solver; 2) DNN-P: A DNN scheme adapted from (Pan et al., 2019). It learns the load-solution mapping using penalty approach without constraints calibration and incorporates a projection post processing if the DNN solution is infeasible; 3) DNN-D: A penalty-based DNN scheme adapted from (Donti et al., 2021). It includes the correction step for infeasible solutions in training/testing; 4) DNN-W: A hybrid method adapted from (Dong et al., 2020a). It trains a DNN to predict the primal and dual variables as the warm-start points to the conventional solver; 5) DNN-G: A gauge function based DNN scheme adapted from (Li et al., 2022). It enforces solution feasibility by first solving a linear program to find a feasible interior point, and then constructing the mapping between DNN prediction in an l_∞ unit ball and the optimum. To better evaluate DeepOPF+, we implement two DeepOPF+ schemes with different DNN sizes and calibration rate (3%, 7%) that are all within the maximum allowable one, namely DeepOPF+-3, and DeepOPF+-7. The detailed designs are summarized in Appendix M.

We use the following performance metrics: (i) the percentage of the feasible solution obtained by DNN, (ii) the average relative optimality difference between the objective values obtained by DNN

---

[5]$P_{G_i} = P_{G_i}^{\min} = P_{G_i}^{\max} = 0, \forall i \notin \mathcal{G}$, and $P_{D_i} = 0, \forall i \notin \mathcal{A}$, where $\mathcal{A}$ denotes the set of load buses.

[6]We remark that the training of DNN is conducted offline; thus, its complexity is minor as amortized over many DC-OPF instances, e.g., 1000 scenarios per 5 mins. Meanwhile, the extra cost to solve the new-introduced programs in our design is also minor observing that existing solvers like Gurobi can solve the problems efficiently, e.g., <20 minutes to solve the MILPs to determine calibration rate and DNN size. Thus, we consider the run-time complexity of the DNN scheme, which is widely used in existing studies.

Table 1: Performance comparison with SOTA DNN schemes in light-load and heavy-load regimes.

Case	Scheme	Average speedups		Feasibility rate (%)		Optimality loss (%)		Worst-case violation (%)	
		light-load	heavy-load	light-load	heavy-load	light-load	heavy-load	light-load	heavy-load
Case30	DNN-P	×85	×86	100	88.12	0.02	0.03	0	5.43
	DNN-D	×85	×84	100	93.36	0.02	0.03	0	11.19
	DNN-W	×0.90	×0.86	100	100	0	0	0	0
	DNN-G	×24	×26	100	100	0.13	0.04	0	0
	DeepOPF+-3	×86	×92	100	100	0.03	0.04	0	0
	DeepOPF+-7	×86	×93	100	100	0.03	0.09	0	0
Case118	DNN-P	×137	×125	68.84	54.92	0.17	0.21	19.5	44.8
	DNN-D	×138	×124	73.42	55.37	0.20	0.24	16.69	43.1
	DNN-W	×2.08	×2.26	100	100	0	0	0	0
	DNN-G	×26	×16	100	100	1.29	0.39	0	0
	DeepOPF+-3	×201	×226	100	100	0.18	0.19	0	0
	DeepOPF+-7	×202	×228	100	100	0.37	0.41	0	0
Case300	DNN-P	×115	×98	91.29	78.42	0.06	0.08	261.1	443.0
	DNN-D	×115	×102	91.99	82.92	0.07	0.07	231.6	348.1
	DNN-W	×1.04	×1.08	100	100	0	0	0	0
	DNN-G	×2.44	×2.65	100	100	0.32	0.06	0	0
	DeepOPF+-3	×129	×136	100	100	0.03	0.03	0	0
	DeepOPF+-7	×130	×138	100	100	0.10	0.06	0	0

*   Feasibility rate and Worst-case violation are the results *before* post-processing. Feasibility rates (resp Worst-case violation) after post-processing are 100% (resp 0) for all DNN schemes. We hence report the results before post-processing to better show the advantage of our design. Speedup and Optimality loss are the results *after* post-processing of the final obtained feasible solutions.

*   The *correction* step in DNN-D (with 10^{-3} rate) takes longer time compared with l_1-projection in DNN-P, resulting in lower speedups.

*   We empirically observe that DNN-G requires more training epochs for satisfactory performance. We report its best results at 500 epochs for Case118/300 heavy-load and the results at 400 epochs for the other cases. The training epoch for the other DNN schemes are 200.

and Pypower, (iii) the average speedup, i.e., the average running-time ratios of Pypower to DNN-based approach for the test instances, respectively. (iv) the worst-case violation rate, i.e., the largest constraints violation rate of DNN solutions in the entire load domain.

6.2.1 PERFORMANCE COMPARISONS BETWEEN DEEPOPF+ AND EXISTING DNN SCHEMES.

The results are shown in Table 1 with the following observations. First, DeepOPF+ improves over DNN-P/DNN-D in that it achieves consistent speedups in both light-load and heavy-load regimes. DNN-P/DNN-D achieves a lower speedup in the heavy-load regime than in the light-load regime as a large percentage of its solutions are infeasible, and it needs to involve a post-processing procedure to recover the feasible solutions. Note that though DNN-P/DNN-D may perform well on the test set in light-load regime with a higher feasibility rate, its worst-case performance over the entire input domain can be significant, e.g., more than 443% constraints violation for Case300 in the heavy-load region. In contrast, DeepOPF+ guarantees solution feasibility in both light-load and heavy-load regimes, eliminating the need for post-processing and hence achieving consistent speedups. Second, though the warm-start/interior point based scheme DNN-W/DNN-G ensures the feasibility of obtained solutions, they suffers low speedups/large optimality loss. As compared, DeepOPF+ achieves noticeably better speedups as avoiding the iterations in conventional solvers. Third, the optimality loss of DeepOPF+ is minor and comparable with these of the existing state-of-the-art DNN schemes, indicating the effectiveness of the proposed *Adversary Sample-Aware* training algorithm. Fourth, we observe that the optimality loss of DeepOPF+ increases with a larger calibration rate, which is consistent with the trade-off between optimality and calibration rate discussed in Sec. 5.3. We remark that DC-OPF is an approximation to the original non-convex non-linear AC-OPF in power grid operation under several simplifications. DC-OPF is widely used for its convexity and scalability. Expanding the work to AC-OPF is a promising future work as discussed in Appendix B.

6.3 APPLICATION TO NON-CONVEX OPTIMIZATION

To better show the advantage of our design, We adopt the non-convex optimization example in (Donti et al., 2021). Detailed design and results are shown in Appendix N.

7 CONCLUDING REMARKS

We propose preventive learning as the first framework to develop DNN schemes to solve OPLC with solution feasibility guarantee. Given a sufficiently large DNN, we calibrate inequality constraints used in training, thereby anticipating DNN prediction errors and ensuring the obtained solutions remain feasible. We propose an *Adversary Sample Aware* training algorithm to improve DNN's optimality. We apply the framework to a non-convex optimization and develop DeepOPF+ to solve and DC-OPF problems in grid operation. Simulations show that it outperforms existing strong DNN baselines in ensuring feasibility and attaining consistent optimality loss and speedup in both light-load and heavy-load regimes. We remark that the proposed scheme can work for large-scale systems because of the desirable scalability of DNN. Future directions include extending the framework to general non-linear constrained optimizations like ACOPF and evaluate the performance over systems with several thousand buses and realistic loads as discussed in Appendix B.

REFERENCES

Power Systems Test Case Archive, 2018. http://labs.ece.uw.edu/pstca/.

Akshay Agrawal, Brandon Amos, Shane Barratt, Stephen Boyd, Steven Diamond, and J Zico Kolter. Differentiable convex optimization layers. *Advances in Neural Information Processing Systems*, 32:9562–9574, 2019.

Brandon Amos and J Zico Kolter. Optnet: Differentiable optimization as a layer in neural networks. In *International Conference on Machine Learning*, pp. 136–145, 2017.

Alberto Bemporad and Carlo Filippi. An algorithm for approximate multiparametric convex programming. *Computational optimization and applications*, 35(1):87–108, 2006.

Alberto Bemporad, Manfred Morari, Vivek Dua, and Efstratios N Pistikopoulos. The explicit solution of model predictive control via multiparametric quadratic programming. In *Proceedings of the 2000 American Control Conference. ACC (IEEE Cat. No. 00CH36334)*, volume 2, pp. 872–876. IEEE, 2000.

Saverio Bolognani and Florian Dörfler. Fast power system analysis via implicit linearization of the power flow manifold. In *2015 53rd Annual Allerton Conference on Communication, Control, and Computing (Allerton)*, pp. 402–409. IEEE, 2015.

Stephen Boyd and Lieven Vandenberghe. *Convex optimization*. Cambridge university press, 2004.

Mary B Cain, Richard P O'neill, and Anya Castillo. History of optimal power flow and formulations. *Federal Energy Regulatory Commission*, 1:1–36, 2012.

Anirban Chakraborty, Manaar Alam, Vishal Dey, Anupam Chattopadhyay, and Debdeep Mukhopadhyay. Adversarial attacks and defences: A survey. *arXiv preprint arXiv:1810.00069*, 2018.

Spyros Chatzivasileiadis. Optimization in modern power systems. *Lecture Notes. Tech. Univ. of Denmark. Available online: https://arxiv. org/pdf/1811.00943. pdf*, 2018.

Minas Chatzos, Ferdinando Fioretto, Terrence WK Mak, and Pascal Van Hentenryck. High-fidelity machine learning approximations of large-scale optimal power flow. *arXiv preprint arXiv:2006.16356*, 2020.

John M Danskin. *The theory of max-min and its application to weapons allocation problems*, volume 5. Springer Science & Business Media, 2012.

Roel Dobbe, Oscar Sondermeijer, David Fridovich-Keil, Daniel Arnold, Duncan Callaway, and Claire Tomlin. Toward distributed energy services: Decentralizing optimal power flow with machine learning. *IEEE Transactions on Smart Grid*, 11(2):1296–1306, 2019.

Wenqian Dong, Zhen Xie, Gokcen Kestor, and Dong Li. Smart-pgsim: using neural network to accelerate AC-OPF power grid simulation. In *SC20: International Conference for High Performance Computing, Networking, Storage and Analysis*, pp. 1–15. IEEE, 2020a.

Yinpeng Dong, Zhijie Deng, Tianyu Pang, Jun Zhu, and Hang Su. Adversarial distributional training for robust deep learning. In *Advances in Neural Information Processing Systems*, volume 33, pp. 8270–8283, 2020b.

Priya L Donti, David Rolnick, and J Zico Kolter. DC3: A learning method for optimization with hard constraints. *arXiv preprint arXiv:2104.12225*, 2021.

Adam N Elmachtoub and Paul Grigas. Smart "predict, then optimize". *Management Science*, 68(1): 9–26, 2022.

Nuno P Faísca, Vivek Dua, and Efstratios N Pistikopoulos. Multiparametric linear and quadratic programming, 2007.

Silvia Ferrari. Multiobjective algebraic synthesis of neural control systems by implicit model following. *IEEE Transactions on Neural Networks*, 20(3):406–419, 2009.

Ferdinando Fioretto, Terrence WK Mak, and Pascal Van Hentenryck. Predicting AC optimal power flows: Combining deep learning and lagrangian dual methods. In *Proceedings of the AAAI Conference on Artificial Intelligence*, volume 34, pp. 630–637, 2020.

José Fortuny-Amat and Bruce McCarl. A representation and economic interpretation of a two-level programming problem. *Journal of the operational Research Society*, 32(9):783–792, 1981.

Neel Guha, Zhecheng Wang, Matt Wytock, and Arun Majumdar. Machine learning for AC optimal power flow. *arXiv preprint arXiv:1910.08842*, 2019.

Kurt Hornik. Approximation capabilities of multilayer feedforward networks. *Neural networks*, 4 (2):251–257, 1991.

Kurt Hornik, Maxwell Stinchcombe, and Halbert White. Multilayer feedforward networks are universal approximators. *Neural networks*, 2(5):359–366, 1989.

Wanjun Huang and Minghua Chen. DeepOPF-NGT: A Fast Unsupervised Learning Approach for Solving AC-OPF Problems without Ground Truth. In *Proc. ICML Workshop*, Jul. 2021.

Wanjun Huang, Xiang Pan, Minghua Chen, and Steven H Low. Deepopf-v: Solving ac-opf problems efficiently. *IEEE Transactions on Power Systems*, 37(1):800–803, 2021.

James Kotary, Ferdinando Fioretto, and Pascal Van Hentenryck. Learning hard optimization problems: A data generation perspective. *Advances in Neural Information Processing Systems*, 34: 24981–24992, 2021a.

James Kotary, Ferdinando Fioretto, Pascal Van Hentenryck, and Bryan Wilder. End-to-end constrained optimization learning: A survey. In *Proceedings of the Thirtieth International Joint Conference on Artificial Intelligence, IJCAI*, 2021b.

Eugene L Lawler and David E Wood. Branch-and-bound methods: A survey. *Operations research*, 14(4):699–719, 1966.

Xingyu Lei, Zhifang Yang, Juan Yu, Junbo Zhao, Qian Gao, and Hongxin Yu. Data-driven optimal power flow: A physics-informed machine learning approach. *IEEE Transactions on Power Systems*, 36(1):346–354, 2020.

Moshe Leshno, Vladimir Ya Lin, Allan Pinkus, and Shimon Schocken. Multilayer feedforward networks with a nonpolynomial activation function can approximate any function. *Neural networks*, 6(6):861–867, 1993.

Meiyi Li, Soheil Kolouri, and Javad Mohammadi. Learning to solve optimization problems with hard linear constraints. *arXiv preprint arXiv:2208.10611*, 2022.

Suttipan Limanond and Jennie Si. Neural network-based control design: An lmi approach. *IEEE Transactions on Neural Networks*, 9(6):1422–1429, 1998.

Rahul Nellikkath and Spyros Chatzivasileiadis. Physics-informed neural networks for minimising worst-case violations in DC optimal power flow. *arXiv preprint arXiv:2107.00465*, 2021a.

Rahul Nellikkath and Spyros Chatzivasileiadis. Physics-informed neural networks for ac optimal power flow. *arXiv preprint arXiv:2110.02672*, 2021b.

Xiang Pan, Tianyu Zhao, and Minghua Chen. Deepopf: Deep neural network for DC optimal power flow. In *2019 IEEE International Conference on Communications, Control, and Computing Technologies for Smart Grids (SmartGridComm)*, 2019.

Xiang Pan, Minghua Chen, Tianyu Zhao, and Steven H Low. DeepOPF: A Feasibility-Optimized Deep Neural Network Approach for AC Optimal Power Flow Problems. *arXiv preprint arXiv:2007.01002*, 2020a.

Xiang Pan, Tianyu Zhao, Minghua Chen, and Shengyu Zhang. Deepopf: A deep neural network approach for security-constrained DC optimal power flow. *IEEE Transactions on Power Systems*, 36(3):1725–1735, 2020b.

Xiang Pan, Wanjun Huang, Minghua Chen, and Steven H Low. Deepopf-al: Augmented learning for solving ac-opf problems with multiple load-solution mappings. *arXiv preprint arXiv:2206.03365*, 2022.

J. H. Park, Y. S. Kim, I. K. Eom, and K. Y. Lee. Economic load dispatch for piecewise quadratic cost function using hopfield neural network. *IEEE Transactions on Power Systems*, 8(3):1030–1038, Aug 1993. ISSN 0885-8950.

Ning Qian. On the momentum term in gradient descent learning algorithms. *Neural networks*, 12 (1):145–151, 1999.

Chongli Qin, Brendan O'Donoghue, Rudy Bunel, Robert Stanforth, Sven Gowal, Jonathan Uesato, Grzegorz Swirszcz, Pushmeet Kohli, et al. Verification of non-linear specifications for neural networks. *arXiv preprint arXiv:1902.09592*, 2019.

Pengzhen Ren, Yun Xiao, Xiaojun Chang, Po-Yao Huang, Zhihui Li, Xiaojiang Chen, and Xin Wang. A survey of deep active learning. *arXiv preprint arXiv:2009.00236*, 2020.

E Riva Sanseverino, ML Di Silvestre, L Mineo, S Favuzza, NQ Nguyen, and QTT Tran. A multi-agent system reinforcement learning based optimal power flow for islanded microgrids. In *2016 IEEE 16th International Conference on Environment and Electrical Engineering (EEEIC)*, 2016.

Fatemeh Sheikholeslami, Ali Lotfi, and J Zico Kolter. Provably robust classification of adversarial examples with detection. In *International Conference on Learning Representations*, 2020.

Haoran Sun, Xiangyi Chen, Qingjiang Shi, Mingyi Hong, Xiao Fu, and Nicholas D Sidiropoulos. Learning to optimize: Training deep neural networks for interference management. *IEEE Transactions on Signal Processing*, 66(20):5438–5453, 2018.

Vincent Tjeng, Kai Y Xiao, and Russ Tedrake. Evaluating robustness of neural networks with mixed integer programming. In *International Conference on Learning Representations*, 2018.

Pravin M Vaidya. Speeding-up linear programming using fast matrix multiplication. In *IEEE FOCS*, pp. 332–337, 1989.

Andreas Venzke, Guannan Qu, Steven Low, and Spyros Chatzivasileiadis. Learning optimal power flow: Worst-case guarantees for neural networks. In *2020 IEEE International Conference on Communications, Control, and Computing Technologies for Smart Grids (SmartGridComm)*, 2020.

Wenchao Xia, Gan Zheng, Yongxu Zhu, Jun Zhang, Jiangzhou Wang, and Athina P Petropulu. A deep learning framework for optimization of miso downlink beamforming. *IEEE Transactions on Communications*, 68(3):1866–1880, 2019.

Zhifang Yang, Kaigui Xie, Juan Yu, Haiwang Zhong, Ning Zhang, and Qing Xia. A general formulation of linear power flow models: Basic theory and error analysis. *IEEE Transactions on Power Systems*, 34(2):1315–1324, 2018.

Yinyu Ye and Edison Tse. An extension of karmarkar's projective algorithm for convex quadratic programming. *Mathematical Programming*, 44(1):157–179, May 1989.

He Yin, Vassilis Kekatos, Ming Jin, et al. Learning neural networks under input-output specifications. *arXiv preprint arXiv:2202.11246*, 2022.

Ahmed S Zamzam and Kyri Baker. Learning optimal solutions for extremely fast AC optimal power flow. In *2020 IEEE International Conference on Communications, Control, and Computing Technologies for Smart Grids (SmartGridComm)*, 2020.

Tianyu Zhao, Xiang Pan, Minghua Chen, Andreas Venzke, and Steven H Low. Deepopf+: A deep neural network approach for dc optimal power flow for ensuring feasibility. In *2020 IEEE International Conference on Communications, Control, and Computing Technologies for Smart Grids (SmartGridComm)*, 2020.